

Technical Guide

TG-19-C-029-E

Ε


Made by: rendav

Date: 11.08.2008

Modifications: see last page

CALIBRE 3303

	Version A Version B	
12''' Ø 27 mm	123 — 123 — 1 1 1 1 II III III	
Height on movement	6.85 mm	
Power reserve Number of jewels Frequency	52 h 33 4 Hz (28'800 A/h)	





Automatic movement, exclusive Omega chronograph, date, COSC certified, Swiss Pallet fork escapement. Chronograph system with column-wheel. 30-min. minute counter and 12-h hour counter + small second hand at 9 o'clock. Omega balance system without index.



	Page
Calibre 3303	1
General information for Calibre 3303 Exchange / Key points / Lubricants / Mandatory tools Tightening and untightening torques according to screw thread size Technical modifications on version «A» and «B» Lubrication of crow wheel and the three driving wheels for rachet wheel	3-7 3 3 4-5 6-7
Differences between the versions for Calibre 3303 Differences between the versions	8
Exploded views for Calibre 3303 Dial side Movement side Movement side Movement side Dial side	9-13 9 10 11 12 13
Spare parts list & illustrations for Calibre 3303 Spare parts & illustrations	14-18 14 15 16 17 18
Specific information for Calibre 3303 Chronograph wheel function / Description of chronograph system Chronograph setting Runners for hand setting and hand setting force / Epilame coating Instantaneous rate	19-23 19 20 21 22
Modifications of Technical Guide versions for Calibre 3303	23

Balance bridge and chronograph bridge

The bridges with serial numbers are not available (see CS-Info Calibre No 33). For exchange, see table:

Exchanges	S		with serial no
Version A	Chronograph bridge (Ref. 722330315040N)	For exchanges always sent to Engravings at Omega within	9

Exchanges		with serial no	
Version B	Balance bridge (Ref. 7223303B10058)	For exchanges always sent to Engravings at Omega within	9

Key points

The three intermediate driving wheels for ratchet wheel (32.083) must be correctly lubricated with Moebius SYNT-HP-1300 Sans Colorant. Insufficient lubrication could lead to the formation of burrs or chips and hinder the correct winding of the barrel. Cleaning would not be sufficient to remove all this. (see page δ and δ).

Due to the movement construction, there are various screw lengths. To avoid problems at assembly, group identical screws together for cleaning.

Swiss pallet fork Escapement lubrication See Working Instruction No 40.

Tightening and untightening torques according to screw thread size

Ø Screw	Tightening torque target cNm	Untightening torque mini cNm
Ø threads ≤ \$ 0.50 mm	1.0	0.7
Ø threads \$ 0.6 mm	1.4	0.8
Ø threads S 0.7 mm	1.8	0.9
Ø threads \$ 0.8 mm	2.2	1.1
Ø threads \$ 0.9 mm	2.6	1.3
Ø threads S 1.0 mm	3.0	1.6
Ø threads S 1.2 mm	3.5	2.0
Ø threads S 1.4 et >	4.0	2.5

OMEGA SA

Mandatory tools:

To fit the hands, the movement must be placede in a suitable, well-adjusted movement holder.

Hand fitting Movement holder for hand fitting Hand fitting tool kit	Reference 507 0001 507 0011
Movement Movement holder Mainspring winder Timing key	Reference 506 0001 502 150 0009 502 200 0501
Lubricants Moebius SYNT-A-LUBE 9010 (2ml) Moebius SYNT HP-1300 Sans Colorant Moebius 9504 Moebius 9415 Moebius SYNT HP-500 Kluber P125	Reference 504 200 0001 504 5013 504 5014 504 100 0003 504 5012 5041000071

Date correction

Date correction should not be performed between
10 pm and 2 am.

Technical modifications on version «A»

	Screw for hammer-lever banking bridge			
Old version	Risk	New version	Improvements	Notes
72233036033	Broken screw head.	72233036034		The new version must be
	Old screw length 1.90 mm with guide. Consequence: start/stop function no longer works. The head or the bridge can block the movement.		New screw length 1.95 mm without guide, threaded to the end, stronger. New version since week 35/2004.	fitted during a maintenance service. If the screw thread cannot be removed from the limitation bridge, the full barrel bridge must be replaced (ref. 722330310041).

	Column wheel operating lever			
Old version	Risk	New version	Improvements	Notes
722330355040		722330355040		
	The column wheel control can bend at the weakest place (see arrow). Consequence: start/stop function does not work.		Stronger. New version since week 32/2003.	The new version must be fitted during a maintenance service. The circled part must under no circumstances be bent or modifi ed!

	Minute counter jumper			
Old version	Risk	New version	Improvements	Notes
722330355143		722330355143		
↓ 🗪	The jumper breaks at the place where it is bent. Consequence: the minute counter can no longer be reset to zero.	_	Stronger. New version since week 32/2003.	The new version must be fitted during a maintenance service.

	Hammer operating lever			
Old version	Risk	New version	Improvements	Notes
722330355047		7223303A55048		
	The first execution can bend. The second execution with reset to zero too strong. In both cases, the chronograph hand is not reset correctly to zero.		The new shape ensures correct resetting to zero and that the hand is held firmly. New version since week 32/2003.	The new version must be fitted during a maintenance service.

OMEGA SA WORLD SERVICE ORGANIZATION GT-19-C-029-E - E - 3303 /4

Technical modifications on version «A» and «B»

	Rocking bar			
Old version	Risk	New version	Improvements	Notes
722330351052		722330351052		
OA	The setting lever might bend due pressure on stem. Consequence: Malfunction of time setting function.		The finger on rocking bar is decreasing this risk. New version available since 27/2008	The new version must automatically be assembled if this case happens.


Customer Service lubrication of stud for crown wheel (31.023) and the 3 intermediate driving wheels for ratchet wheel (32.083):

With the aim of constantly improving the performances and reliability of Omega products, the lubrication in Customer Service has been updated.


Amount of lubricant to be applied:

- On the crown wheel stud and the stud for the three ratchets intermediate driving wheels during a service.


Lubrication of stud for crown wheel (Moebius 9504)




Stud for crown wheel













Lubrication of the 3 intermediate driving wheels for ratchtet wheel (HP 1300 Sans Colorant) $\,$








Differences between Calibre 3303A and 3303B

	3303A (4 Hz)	3303B (4 Hz)
Main plate		
	Ref. 722330310020 Ø Hole for dial fastener: 0.80 mm	Ref. 7223303B10020 Ø Hole for dial fastener: 1.00 mm
Balance bridge, complete	Ref. 722330310058	Ref. 7223303B10058
Balance, complete		
	Ref. 722330340055 Cylindrical pivots Ø 0.08 mm	Ref. 7223303B40055 Conical pivots Ø 0.07 mm
Shock-absorber, upper	Ref. 722330332025 Jewel hole Ø 0.09 mm Nickel-plated	Ref. 7223313B32027 Jewel hole Ø 0.08 mm Gold-plated
Shock-absorber, lower	Ref. 722330332062 Jewel hole Ø 0.09 mm Nickel-plated	Ref. 7223303B70531 Jewel hole Ø 0.08 mm Gold-plated
In setting, upper	Ref. 7223303A32127 Jewel hole Ø 0.09 mm	Ref. 7223313B32127 Jewel hole Ø 0.08 mm
In setting, lower	Ref. 7223303A32167 Jewel hole Ø 0.09 mm	© Ref. 7223313B32167 Jewel hole Ø 0.08 mm




```
\begin{array}{lll} 1 = 10020 & 7 = 51050 \\ 2 = 31121 & 8 = 61100 \\ 3 = 31120 & 9 = 33082 \\ 4 = 51010 & 10 = 51052 \\ 5 = 51083 & 11 = 51090 \\ 6 = 6407 (1x) & 12 = 7035 (2x) \end{array}
```


Moebius SYNT HP-1300 Sans Colorant



Moebius SYNT HP-1300 Sans ColorantMoebius SYNT-A-LUBE 9010


Moebius 9504





Moebius SYNT HP-500

Moebius SYNT HP-1300 Sans Colorant



1 = 31102 8 = 53080 2 = 33083 9 = 91440 3 = 53200 10 = 63030 4 = 31080 11 = 13105 5 = 31041S2 12 = 6210 (4x) 6 = 33020 13 = 31046 7 = 33011 14 = 66220

- Moebius SYNT-A-LUBE 9010
- ► Moebius 9504
- Moebius SYNT HP-1300 Sans Colorant

